



Certificate of Compliance

Certificate: NA202111540

Date Issued: December 2, 2021

Project: 438606-6.1

Issued to: Conspec Controls Inc.
6 Guttman Blvd.
Charleroi, PA 15022
USA

The products listed below have been certified as being compliant with all applicable requirements of the specifications listed and are eligible to bear the following certification mark



Authorized by:

Simon Huang,
Certifier, Nemko Group Certification

PRODUCTS

MEASUREMENT, CONTROL, OR LABORATORY EQUIPMENT - Certified to US and Canadian Standards

Product: Optio V

Model: CPR-VCxx-52-xx; CPR-VCxx-20-xx

The first "xx" can be:

- Blank = relay only system
- M = Modbus
- A = 4-20mA
- MA = Modbus and 4-20mA

The second "xx" can be:

- Blank = no remote sensors
- 1 = One remote sensor
- 2 = 2 remote sensors
- NS = no sensors

Ratings: 12-24Vac, 50/60Hz (CPR-VCxx-52-xx); 12-24Vdc (CPR-VCxx-20-xx)

APPLICABLE REQUIREMENTS

UL Std. No. 61010-1 3rd Edition + AM1:2018 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use – Part 1: General Requirements

CAN/CSA-C22.2 No. 61010-1-12 Third Edition + AM1:2018 – Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use – Part 1: General Requirements

This certificate is issued on condition that the holder complies and will continue to comply with the requirements of the above mentioned specifications and pursuant to the terms and conditions specified in the Certification Agreement.



Supplement to Certificate of Compliance

Certificate: NA202111540

Project: 438606-6.1

Customer Number: 266900

Nemko North America grants a license to the applicant to apply the Certification Mark to the certified products and that the mark shall only be affixed at the following factory locations

Factory Information

Factory Name	Factory Number	Location
Conspec Controls Inc.	266900	6 Guttman Blvd. Charleroi, PA 15022 USA

Product Certification History

Project	Date	Description
438606-6.1	December 2, 2021	Original Certification: Model: CPR-VCxx-52-xx; CPR-VCxx-20-xx Ratings: 12-24Vac, 50/60Hz (CPR-VCxx-52-xx); 12-24Vdc (CPR-VCxx-20-xx)

This Supplement forms an integral part of the Certificate of Compliance